



# EC CERTIFICATE

Fire Resistance of Lift Landing Doors

CERTIFICATE NR: LF-615312024

**ATERYA TEKNİK MÜHENDİSLİK HİZMETLERİ LTD. ŞTİ.**

Arı San. Sitesi 22.cadde 690 sokak No:67 OSTİM - ANKARA - TURKEY

Product Description : Fire resistant side opening (telescopic) lift landing door.

Product Type : KT-2T  
(900 x 2000) mm (width x height)

Basis of the certificate: 95/16/EC Lift Directive, EN 81-58:2003

**CLASSIFICATION : E 60**

Test Report : RFTR12006 / EFECTIS ERA AVRASYA

Conclusion : Fire resistant central opening lift landing door meets the requirements of the Lift Directive, Annex I section 4.2 and the EN 81-58:2003, in particular for the classification indicated above.  
Classification results are considered to be applicable to doors of size within the tolerance of  $\pm 30$  % width and  $\pm 15$  % height if all other constructional details being the same from those of type.

Date of issue: 01/06/2012

Director

**SZUTEST**  
TEKNİK KONTROL VE  
BELGELENDİRME  
HİZM. TİC. LTD. ŞTİ.

İnönü Mah. Kayışdağı Cad.No: 148 Kat 3-4  
ATAŞEHİR - İSTANBUL - TÜRKİYE  
Tel: +90 216 469 46 66 Fax: +90 216 469 46 67  
web: szutest.com.tr e-mail: info@szutest.com.tr

